



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2018-02-26-09 Date: 09/03/2018
Customer : Assistant Executive Engineer, Dasarahalli Sub division, BBMP, Bangalore.
Address : Dasarahalli Sub division, BBMP, Bangalore.
Project Name : Providing and sinking of borewells, pump, motor and water supply lines in ward no.14 Bagalagunte.
Agency : Technical Manager (West), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main road, 3rd 'Y' Block, Rajajinagar, Bangalore-560010.
Customer's Reference : BBMP/EE/DD/WO/121/2017-18
Source of Sample : Sample supplied by Agency
Sample Condition : Satisfactory
Date of Receipt : 26-02-18
Sample ID No : 2018-02-26-09 /01
Customer ID : PCC
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M15 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 09/03/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	PCC	M15	02/03/2018	09/03/2018	151.00 X 150.24 X 150.47	22686	8.147	306.3	13.5	13.1
2	PCC	M15	02/03/2018	09/03/2018	149.87 X 150.66 X 150.47	22579	8.165	295.8	13.1	
3	PCC	M15	02/03/2018	09/03/2018	150.14 X 150.98 X 151.36	22668	8.174	290.2	12.8	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

Signature
ಕಾರ್ಯಕರ್ತೃ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು
Page 1/1
****End of Report****



FOR CIVIL Pro.
Signature
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |